## 2. For eTender 748 :Selection of Solution Provider (SP) for Supply, Installation and Commissioning of Data Center Passive components and Revamp DC at MPCB

Sr. No	RFP Page no.	RFP Section	RFP Content	Clarification Sought	MPCB Response
1	36	9.2.(2)	An amount equivalent to 90% of the cost of the equipment value will be paid on supply, installation and commissioning of all the equipments with all the features to MPCB's satisfaction.	Request to release 90% of the cost of the equipment value after supply of the equipment	Clause remains unchanged
2	45	Annexure-2	Biometric access control system	Whether STQC certification is necessary for the product	STQC certification is not mandatory
3	24	Exhibit-3	Manufacturer's Authorisation Form		MAF is mandatory for all the products quoted from respective manufacturer
4	55	Annexure-4	Price bid format A		Revised Price bid format is Attached as Annexure-II
5				Request to allow physical assessment of DataCenter	Each participating Bidder who have purchased the Tender will be given individual slots of 2 Hrs on 26th/27th Oct during working hours of MPCB with prior written approval from MPCB. Bidder must produce proof of purchase of tender while visiting DC. No photography is allowed, however bidder can draw schematics for their reference.
6				Electrical SDL diagram	Please refer to point no 5 above.
7				Makes of Material is missing	Bidder can supply material of any make provided it is compliant as mentioned in RFP (Annexure -2) and accompanied by MAF and Manufacturer's declaration about Technical compliance (Exhibit-3 and Exhibit-4)
8				Availability of DG set	DG set is not available
9				UPS scope	Supply of UPS is not in the Bidder's scope, however supply and laying adequate & appropriate electrical cable from UPS to DC is in scope of bidder.
10				Whether there is Epoxy coating on DC flooring	Currently there is no Epoxy coating on DC floor
11			_	Detailed BOQ is missing	It is bidders responsibility to give the BOQ after duly visiting DC and estimating quantum of work. Bidder should include the BOQ in Technical Bid and Quote. Format for BOQ is

2.8.2

e 481

attached as Annexure –I (NO PRICE TO BE QUOTED IN BOQ)
Revised Price bid format is Attached as Annexure-II

## ANNEXURE-I

## DETAILED BOQ FORMAT (AS A PART OF TECHNICAL BID)


Sr No	Product/ Service Code	Make	Description	Qty
1				
2				
3				
1				

P.J.O.

P.S.M.

## ANNEXURE-II





Note: Commercial Offer has to be entered online only. An <u>Online Form</u>, similar to the Commercial format given below, will be available to the bidders in Commercial Envelope (C1) during Online Bid Preparation stage where bidders would quote their offer.

The bidders should strictly follow the format given below for submitting the price -bids

Sr. No	Description	Basic Material / Service Price w/o GST (Rs.) A	GST Rs.	One time Installation / Setup Cost w/o GST (Rs.) B	GST Rs.	
1	Interior work including Civil, Electrical, Cable laying, Carpentry, Water proofing, Painting					
2	Fire alarm with fire suppression solution					
3	PAC solution					
4	Water leakage detection solution					
5	Rodent repellent solution					
6	Access control solution					
7	CCTV and Surveillance solution					
8	Support cost for 3 years					
9	Other (please specify)					
Sub Totals Rs. A B						
GRAND TOTAL T=(A+B) Rs.						

Grand	Total Amount in Words Rs.:	11000
Note:	<ol> <li>The prices are valid for 180 days from the date of bid.</li> <li>The prices quoted are for the scope as mentioned in Annexure of 3 year AMC</li> <li>The prices quoted are as per detailed BOQ attached in Technic</li> <li>We Undertake that no additional material will be required and in provided at no extra cost to MPCB</li> <li>Orders will be released in accordance with GST norms for Goo (Breakup of TAX structure to be given Item-wise by the bidder)</li> </ol>	al Bid f required will be
For and	d on behalf of:	
Signatu	re (Authorized Representative and Signatory of the Bidder):	
Name of Design	of the Person:	
Date:		*